

Commonwealth of Kentucky
Division for Air Quality
EXECUTIVE SUMMARY

FINAL

TITLE V PERMIT NO. V-03-052 R1

CORNING, INCORPORATED

680 EAST OFFICE STREET, HARRODSBURG, KENTUCKY

APRIL 3, 2008

MARTHA M. ALLMAN, REVIEWER

SOURCE I.D. #: 21-167-00004

SOURCE A.I. #: 3143

ACTIVITY ID #: APE20070001

CURRENT PERMITTING ACTION:

On July 20, 2007, an application was received from Corning, Inc. to add nine emergency diesel generators and one emergency diesel air compressor to its existing Title V permit, V-03-052. These units will only be used during a power failure, which Corning, Inc. estimates not to exceed 55 hours per year for the generators and 52 hours per year for the air compressor. The application was filed as a minor revision, but upon review, the Division determined that pursuant to 401 KAR 52:020 Section 14(d), this application should be processed as a major revision since a federally enforceable emissions cap is involved.

PUBLIC AND AFFECTED STATE REVIEW:

On January 10, 2008, the public notice on availability of the draft permit and supporting material for comments by persons affected by the plant was published in *The Harrodsburg Herald* in Harrodsburg, Kentucky. The public comment period expired 30 days from the date of publication. No other states are affected by this permit action.

No comments were received during this period. The final determination of this Division is that the proposed operation will comply with all air quality regulations and requirements. A final permit will be issued after the U.S. EPA's 45-day review.

U.S. EPA REVIEW:

The U.S. EPA was notified of the issuance of the proposed permit on February 18, 2008 via e-mail. The comment period expired 45 days from the date of e-mail. No comments were received during this period. The permit is now being issued final.